



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA160466

Date of Issue: 22 March 2016

Class Description: Non-Declared

Product Description: Temporary Fire Alarm System
(Rechargeable Battery powered Control panels,
Non-rechargeable battery powered call points)

Additional Models

Description

CYG14-GSM/GPRS

Control Panel with Remote Monitoring,
6V 1.2Ah Lead Acid Rechargeable Yuasa Battery

CYG24-AUS/NZ

Fire Alarm Call Point with Alkaline Battery Pack,
6V 1.2Ah Lead Acid Rechargeable Yuasa Battery

CYG24L-AUS/NZ

Fire Alarm Call Point with Lithium Battery Pack,
9V - 6 x D Duracell Industrial Battery pack 18Ah

CYG24PIR-AUS/NZ

Fire Alarm Call Point with Alkaline Battery Pack & PIR Sensor,
10.8V - 3 x D ACT Cell Lithium Metal Battery Pack 14.5Ah

CYG24LPIR-AUS/NZ

Fire Alarm Call Point with Lithium Battery Pack & PIR Sensor,
9V - 6 x D Duracell Industrial Battery pack 18Ah

CYG24/85DB-AUS/NZ

Fire Alarm Call Point (85dB) with Alkaline Battery Pack,
10.8V - 3 x D ACT Cell Lithium Metal Battery Pack 14.5Ah

CYG24/85DBL-AUS/NZ

Fire Alarm Call Point (85dB) with Lithium Battery Pack,
9V - 6 x D Duracell Industrial Battery pack 18Ah

CYG24/85DBPIR-AUS/NZ

Fire Alarm Call Point (85dB) with Alkaline Battery Pack & PIR Sensor,
10.8V - 3 x D ACT Cell Lithium Metal Battery Pack 14.5Ah

CYG24/85DBLPIR-AUS/NZ

Fire Alarm Call Point (85dB) with Lithium Battery Pack & PIR Sensor,
9V - 6 x D Duracell Industrial Battery pack 18Ah


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 22-03-16 160466/2